

# An Evaluation of the Status of Diablo Canyon Unit 1 with Respect to Reactor Pressure Vessel Condition Monitoring and Prediction

Mark Kirk

*Phoenix Engineering Associates, Inc.*

*Unity, New Hampshire*

[kirk@peaiconsulting.com](mailto:kirk@peaiconsulting.com)

PEAI

**DCISC Public Meeting**

Alvia Beach, California  
21 February 2024



**Phoenix  
Engineering  
Associates  
Inc.**



## **BACKGROUND**

Administrative. Embrittlement measurement & prediction. RPV integrity management.



## **NRC REQUIREMENTS & GUIDANCE**

For monitoring & embrittlement prediction. For structural integrity



## **EVALUATION OF DIABLO CANYON UNIT 1**

Surveillance program. NRC's required analysis. Supplemental analysis.



## **ANSWERS TO PUBLIC'S CONCERNS**



# Administrative Documentation

- **Objectives**

- Address concerns raised by SLOMFP, FOE, & Mr. B. Severance
- Independent evaluation of Unit 1 RPV condition

- **Two reports**

- Part 1 addresses public's concerns
- Part 2 evaluates the embrittlement of the Diablo Canyon Unit 1 reactor pressure vessel (RPV)

- **Reports reviewed by**

- DCISC consultants
- DCISC members individually
- PG&E to check for omissions & errors of fact only

Reviews did not affect report conclusions

## An Evaluation of the Status of Diablo Canyon Unit 1 With Respect to Reactor Pressure Vessel Condition Monitoring and Prediction

Part 1: Addressing Public Concerns

Consultant's report to the Diablo Canyon Independent Safety Committee

Submitted by  
Mark Kirk  
Phoenix Engineering Associates Inc.  
Unity, New Hampshire, USA

Date: 26 January 2024



<https://www.dcisc.org/>

An Evaluation of the Status of Diablo Canyon Unit 1 With Respect  
to Reactor Pressure Vessel Condition Monitoring and Prediction

[Letter Transmitting Two Reports by Dr. Mark Kirk to the DCISC](#) (PDF)

[Report Part 1: "Addressing Public Concerns."](#) (PDF)

[Report Part 2: "Evaluation of Diablo Canyon Unit 1 Embrittlement."](#)  
(PDF)

# Administrative

Where are public's concerns addressed?

## Concerns

### Continued Operating Safety of Unit 1

- Data credibility
- Surveillance capsule withdrawal plan
- Use of similar (“sister plant”) data
- RPV beltline inspections
- Alternate testing methods (nano indentation)
- Alternative Charpy analysis method
- Aspects of the RPV analysis methodology
- Deficient materials



BACKGROUND



NRC REQUIREMENTS AND GUIDANCE



EVALUATION OF UNIT 1



ANSWERS TO PUBLIC'S CONCERNS



# 1. Background

Part 1 Report  
Section 2.1, 2.2, and 2.3

## **Key terms**



- Embrittlement
- Fracture toughness
- Surveillance program

## **Embrittlement forecasting**

## **Assessment of RPV Integrity (Screening Criteria)**

# Embrittlement


- Embrittlement reduces the steel's resistance to failure
  - Embrittlement changes RPV steel at a microstructural level
    - Embrittlement does not cause cracking
    - Embrittlement does reduce energy absorbed by the steel before fracture
      - Increase in Charpy transition temperature ( $T_{41J}$ )
      - Reduction in Charpy upper shelf energy (USE)
- Embrittlement occurs progressively over the plant's operating life
  - Faster early in life
  - Slower as plants age
  - Steel composition affects embrittlement rate




# Fracture Toughness

- Fracture toughness needed to assess plant structural integrity (ASME, NRC)
- Charpy specimens have a machined notch, while fracture toughness is measured using a specimen with a sharp fatigue crack
- Charpy  $T_{41J}$  data correlates well with fracture toughness


## ③ Correlation



## ① Measure Charpy




## ② Want fracture toughness



# Surveillance Program

**1**

Surveillance capsules are loaded with specimens.




# Surveillance Program

2

Surveillance capsules are placed inside the RPV. Capsule distance from fuel determines capsule lead factor (LF).

$$LF(A) > LF(B) > LF(C)$$




# Surveillance Program

## 3

Higher lead factors provide greater advance information on RPV embrittlement.

- Specimens in capsules experience more embrittlement than the RPV
- Specimens represent the RPV condition years into the future
- Long intervals between capsule withdrawals are acceptable




# Surveillance Program & Embrittlement Forecasting

## 4


Capsule data & predictive model forecast future RPV embrittlement

- Both surveillance data and  $T_{41J}$  model are used to forecast future embrittlement
- After 1<sup>st</sup> capsule Unit 1 is not extrapolating to higher fluences than in the RPV



# Assessment of RPV Integrity

- Screening criteria ensure material resistance to fracture exceeds structural driving force
  - Pressure-Temperature operating limits
    - Per ASME Code (shown)
  - Pressurized thermal shock
    - $RT_{PTS} < 132\text{ }^{\circ}\text{C}$  for axial welds
  - Upper shelf energy
    - $USE > 68\text{ Joules}$



\* - not allowed without additional justification, plant modification, or testing

## Screening criteria

- Are not a failure condition
- Are conservatively established at a low failure probability
- Indicate need for additional actions to demonstrate adequate margins
- NRC requires action plan 3 years in advance



## 2. NRC Requirements & Guidance

Part 1 Report  
Section 2.4 and 2.5


### **Embrittlement monitoring & prediction**

- 10CFR 50 App. H
- RG 1.99 Rev 2
- NUREG-1801

### **RPV Integrity**

- 10CFR 50 App. G
- 10 CFR 50.61
- 10 CFR 50.61a

# Embrittlement Monitoring

- NRC 10CFR50 Appendix H sets requirements for surveillance during the initial 40-year license. Incorporates ASTM standard by reference
  - Unit 1 licensed to ASTM E185-70, which requires 3 capsules
  - Same requirements for 50.61 and 50.61a
- NUREG-1801: NRC recommendations for license renewal (beyond 40 years)
  - Compliance with E185-82 recommended 
  - More capsules needed during license renewal if
    - Highest fluence is < 60-year fluence, or
    - The  $\Delta T_{41J}$  predicted at 60-years increases the number of capsules per ASTM E185-82 table


## **ASTM E185-82**

Predicted $\Delta T_{41J}$ on Vessel ID at EOL Fluence [°C]	# of Capsules Required
< 56 °C	3
56 - 111 °C	4
> 111 °C	5

- Last capsule withdrawn between 1x & 2x EOL fluence
- Monitoring of limiting plate and limiting weld required

# Embrittlement Prediction


- Reg Guide 1.99 Rev 2 provides NRC's embrittlement prediction models
- Formulas estimate  $\Delta T_{41J}$  and %drop of USE
- The  $\Delta T_{41J}$  formula (reference temperature shift)
  - Is required by the PTS rule (10CFR 50.61)
  - Is used by custom for P-T limits (ASME Code)
  - Alternate PTS rule (10CFR50.61a) requires a different model
- Guidance and requirements for what data to use are provided ("credibility") ... next slides



# Embrittlement Prediction (Credibility)

- Guidance and requirements for what data to use are provided (“credibility”)

What is credibility?	Credible data follows RG predicted trends
	Not credible data deviates from these trends (see diagram)*



Total # of $\Delta T_{41J}$ Measurements	Max # of data allowed outside shaded bounds in a credible data set
2-3	0
4-6	1
7-9	2
10-12	3

\* This is one of RG1.99's five credibility criteria. Unit 1's compliance with this criteria has been questioned.


# Embrittlement Prediction (Credibility)

- Guidance and requirements for what data to use are provided (“credibility”)

What is credibility?	Credible data follows RG predicted trends
	Not credible data deviates from these trends (see diagram)
How is credibility assessed?	On the whole dataset (all data is either credible or not credible)
	Different rules apply to $\Delta T_{41J}$ and USE %drop data
Why does credibility matter?	Credible data are used to adjust $\Delta T_{41J}$ and USE %drop predictions
	Not-credible data are modeled more conservatively using RG formulas
What data are used?	For PTS, use of plant-specific data and similar data from “sister plants” is required. P-T limits follow this practice by convention, not requirement.
	For USE assessment, 10CFR50 Appendix G makes no statements about “sister plant” data. Sister plant data is not typically used.

# RPV Integrity Screening Criteria (not limits)

Event	NRC Rule	Mechanical Property	Screening Criteria
Pressure-Temperature Limits for Heat Up and Cool Down	10 CFR 50 App G	USE	USE > 68J
Pressurized Thermal Shock	10 CFR 50.61	$\Delta T_{41J}$	NRC Incorporates ASME Code: Section XI, Appendix G
	10 CFR 50.61a		<ul style="list-style-type: none"> <li>• Axial Weld <math>RT_{PTS} &lt; 132\text{ }^{\circ}\text{C}</math></li> <li>• Plate or Circ Weld <math>RT_{PTS} &lt; 149\text{ }^{\circ}\text{C}</math></li> </ul>



## Screening criteria

- Are not a failure condition
- Are conservatively established at a low failure probability

TABLE 1—PTS SCREENING CRITERIA

Product form and $RT_{MAX-X}$ Values	$RT_{MAX-X}$ limits [ $^{\circ}\text{F}$ ] for different vessel wall thicknesses <sup>6</sup> ( $T_{WALL}$ )		
	$T_{WALL} \leq 9.5$ in.	$9.5$ in. $< T_{WALL} \leq 10.5$ in.	$10.5$ in. $< T_{WALL} \leq 11.5$ in.
Axial Weld $RT_{MAX-AW}$ .....	269	230	222
Plate $RT_{MAX-PL}$ .....	356	305	293
Forging without underclad cracks $RT_{MAX-FO}^7$ .....	356	305	293
Axial Weld and Plate $RT_{MAX-AW} + RT_{MAX-PL}$ .....	538	476	445
Circumferential Weld $RT_{MAX-CW}^8$ .....	312	277	269
Forging with underclad cracks $RT_{MAX-FO}^9$ ...	246	241	239

### 3. Diablo Canyon Unit 1 Evaluation

Part 2 Report  
Sections 2, 3, and 4

#### **Surveillance Program**

- Program status
- Capsule B deferrals

#### **Evaluation based on NRC requirements**

#### **Supplemental Evaluation**

# Diablo Canyon Unit 1 Surveillance Program

- Program licensed to ASTM E185-70
  - 3 capsules required over 40-years
  - Requirement fulfilled since 2002
- Capsule B deferrals were appropriate because only 3 capsules required in first 40-years
  - NRC 2006 letter (ML061660220) does not make Cap-B testing a condition of recovery of low power testing time into Unit 1's licensed life (September 2021 → November 2024)
- During license renewal (40 → 60 years)
  - NUREG-1801 recommends testing 2 more capsules based on ASTM E185-82 guidance & Unit 1 estimated embrittlement
  - Testing of Cap-B planned for the next refueling outage in 2025 (DCL-23-118, ML23311A154), recommended before 2028
- Palisades "sister plant" data incorporated in 2011, provides 60+ year fluence data

Capsule ID	Lead Factor	Removal Year	Status
S	3.46	1986	Tested
Y	3.44	1992	
V	2.26	2002	
T	3.44	1992	Removed, Not Tested
Z	3.44	1992	
U	1.28	TBD	Standby
X	1.28	TBD	
W	1.28	TBD	
A	1.31	TBD	Planned Removal & Testing
B	3.46	2025	
C	3.46	2004	Removed, Not Tested
D	3.46	2004	


**Contains limiting weld**

- 3 capsules required for first 40 years, Capsule B deferrals therefore appropriate.
- Capsule B testing recommended by 2028. Capsule B data may alter PTS and USE assessments.



# NRC Required PTS Analysis

## 0 Capsules (1985-1987)



- Surveillance data
- ✕ Estimated  $RT_{PTS}$  at 40 years
- ✕ Estimated  $RT_{PTS}$  at 60 years


PTS Screening Criteria (+132  $^{\circ}C$ )

1985-1987 is the only time during Unit 1 operation that  $RT_{PTS}$  estimates extrapolate beyond the current neutron exposure level (fluence) of the reactor

Generic Unirradiated  $RT_{NDT} = -56^{\circ}F$  or  $-49^{\circ}C$


# NRC Required PTS Analysis

## 1 Capsule (1987-1993)




# NRC Required PTS Analysis

## 2 Capsules (1993-2003)



# NRC Required PTS Analysis

## 3 Capsules (2003-2011)




- Surveillance data
- × Estimated  $RT_{PTS}$  at 40 years
- × Estimated  $RT_{PTS}$  at 60 years

PTS Screening Criteria (+132 °C)

Capsule V,  $\Delta T_{41J} = 209^\circ\text{F}, 116^\circ\text{C}$

# NRC Required PTS Analysis

## 3 Capsules & Palisades (2011-today)




- Embrittlement is nonlinear
  - 0-20 years:  $RT_{PTS} \uparrow \approx 100$  °C
  - 40-60 years:  $RT_{PTS} \uparrow \approx 15$  °C
- Credibility assessed using all available data. Entire set is credible, or not.
- Current  $RT_{PTS}$  estimates are interpolations.
- My calculations validate PG&E's.

Palisades,  $\Delta T_{41J} = 249 \text{ \& } 265$  °F,  $138 \text{ \& } 147$  °C


# NRC Required Analysis for USE

- NRC requires that the RG1.99 model (black curve) be adjusted to bound all credible data (red curve)
  - For Unit 1 the adjustment is minor
- NRC is silent on the use of similar sister plant data for USE assessments
  - USE data from sister plants not typically used



# NRC Required Analysis for USE

- This analysis suggests that Unit 1 will not fall below NRC's 68J screening criteria until long after 60 years
- My calculations validate those of PG&E from 2011 until today
  - PG&E made a small error in 2003 on credibility assessment for USE. This was identified in an NRC “request for additional information” and corrected
  - Error was in conservative direction. Negligible impact on prediction.



# Supplemental Analysis

## Objective

Use more data and more modern analytical techniques\* to help inform judgements concerning

- Confidence in existing techniques
- Need, or not, for additional testing and analysis



\* Techniques not yet endorsed by ASME or NRC



# Supplemental Analysis

## More Data

- Used a machine-learning inspired technique to identify data with similar embrittlement characteristics to the Unit 1 weld
  - Intent is the same as for “sister plants,” but based on more objective / physically based similarity metrics
  - Similarity based on copper, nickel, and irradiation temperature
  - Used international ASTM database




<https://www.sciencedirect.com/science/article/abs/pii/S0022311522003725?via%3Dihub>

# Supplemental Analysis

## More Data

- Data similar to Diablo Canyon 1 weld:
  - Palisades
  - Two PWRs in Germany
- Shows NRC curve provides a conservative representation of data similar to the Diablo Canyon Unit 1 weld



# Supplemental Analysis

## Modern Analytical Techniques

- For PTS and P-T limits ( $\Delta T_{41J}$  data)
  - Used **draft** ASME Code Case N-914
  - Permits use of fracture toughness data (available for Diablo weld in EPRI MRP-127)
  - Permits use of a modern trend curve (ASTM E900-15)
  - **Now in review: not yet approved by either ASME or NRC**
- For USE
  - Used additional data with standard RG1.99R2 analysis process
  - Advanced techniques using fracture toughness data are available [RG1.161, ASME SC-XI App-K] but were not used in this study

### **DRAFT CODE CASE N-914**

Section XI Record No. 19-1113


**Accounting for the Effect of Embrittlement on Fracture Toughness Properties Used in Evaluations of Pressure Boundary Materials in Class 1 Ferritic Steel Components, Section XI, Division 1**

<https://www.epri.com/research/products/000000003002020911>

# Supplemental Analysis

## PTS

- Analysis shows larger distance from the PTS screening criteria than standard NRC analysis (larger margin)
- Fracture toughness data demonstrates the level of conservatism in the current NRC approach




- Greater margin exists than suggested by NRC approach
- PTS screening criteria not exceeded until well after 60 years of operation

# Supplemental Analysis

## USE

- Consideration of similar USE data & the RG1.99R2 method suggests Unit 1 will fall below the NRC 68J screening criteria before 60 years ( $\approx$  2029-2030)
- This could be addressed by performing an “equivalent margins analysis” (EMA) following RG1.161
- EMAs performed on other plants show, without exception, the acceptability of lower USE values



- Unit 1 may fall below USE screening criteria by  $\approx$ 2030
- Further analysis using RG1.161 very likely to demonstrate acceptability through 60 years
- Screening criteria are not failure conditions

## 4. Answers to Public Concerns

Part 1 Report  
Section 3



### **Credibility**

- **Sister Plant Data**
- **RPV beltline inspections**
- **Alternate testing methods (nano indentation)**
- **Alternative Charpy analysis method**
- **Aspects of the RPV analysis methodology**
- **Deficient materials**

# Sister Plant Data

- Concern

- “the accumulation of damage depends upon the *temperature* history of the component, i.e., on the power level history”
- “the complex nature of radiation embrittlement ... is *idiosyncratic* to individual reactors and may change unexpectedly over time”

- **Review on sister plant data**

- Provides similar data to the plant of interest
- Required for PTS
- No guidance for USE

- **Plant *temperature* history**

- Temperature affects embrittlement
- Most time plant is at 100% power ( $\approx 285\text{ }^{\circ}\text{C}$ )
- Plant is at higher temperature at lower power
- 100% power temperature is used (conservative)

- **Reactor specific variables other than temperature**

- Magnitude of effect on  $\Delta T_{41J}$  small
- Existing trend curves predict embrittlement in many types of light water reactors well
- *Idiosyncratic* plant-specific effects not seen

# RPV Beltline Inspections

## Concerns

- The **small number of indications** found by UT inspections of Unit 1 are **not plausible**. Many more flaws found in Belgian RPVs and in predictions of models (FAVOR & GRIZZLY)
  - The **UT inspection interval permitted is too long**, especially because Unit 1 is significantly embrittled
  - Material damage by **hydrogen embrittlement not considered**
- **Small number of indications not plausible**
    - Reason for flaws in Belgian reactors not plausible for Unit 1
    - FAVOR and GRIZZLY models ultra-conservative
    - Indication density in Unit 1 similar to industry experience
  - **UT inspection interval too long**
    - Embrittlement does not cause cracking
    - UT cannot detect embrittlement
    - Unit 1 inspection interval is appropriate and allowed by ASME & NRC
  - **Hydrogen embrittlement not considered**
    - No evidence of hydrogen cracking in a light water RPVs
    - The stainless-steel liner protects the RPV steel
    - Liner cracking prevented by water chemistry control (low oxygen)



# Alternative Testing Methods

## Concern

- Proposal to use Nano-Indentation data to further investigate the embrittlement status of the Diablo Canyon Unit 1 weld samples
- Technique developed by Prof. Hosemann at UC Berkley



- Prof. Hosemann's work is well documented in the literature
- Hardness can be related to fracture toughness using multiple correlations
  - Hardness  $\rightarrow$  strength
  - Strength  $\rightarrow$  fracture toughnessEach correlation introduces uncertainty to the final predicted value.
- No precedent exists for using fracture toughness inferred from hardness in regulatory decisionmaking
- Lack of precedent and compounding uncertainties complicates interpretation of any data collected
- If supplemental data are needed, direct fracture toughness ( $T_0$ ) testing using the "mini-CT" specimen & ASTM E1921 for which there is regulatory precedent would produce clearer outcomes

# Alternative Charpy Analysis Method

- Concern

- Existing methodology not sufficiently accurate
- Prof. Macdonald proposed a new Charpy metric (Extent of Embrittlement: EoE)

- I assessed the accuracy of Charpy metrics ( $T_{41J}$  and EoE) by evaluating how well they predict the fracture toughness transition temperature ( $T_0$ )
- Used data from a wide variety of RPV steels before and after irradiation (see <https://doi.org/10.1115/1.3109987>)
- EoE predicts fracture toughness transition temperature less accurately than  $T_{41J}$



# RPV Assessment Methodology

## Concerns

- “Why has no account been taken for the stainless-steel **liner** in determining the susceptibility of the RPV to brittle fracture & hence a LOCA?”
- “Why has no attention been given to low temperature thermal **annealing** of radiation damage”
- “there were still concerns expressed by PG&E ... regarding the **nozzle** shell welds [who admitted] ... that the nozzle shell welds and related components may not meet fracture toughness limits through the entire 20-year extension”


- **Cladding (liner)**
  - Defects accounted for conservatively by the PTS screening criteria
  - High toughness stainless steel cladding is ignored by structural integrity calculations (conservative)
- **Low temperature annealing**
  - Effect quantified directly by surveillance data
  - Trend curves reflect temperature effects
- **Accounting for steels in nozzle course**
  - Apparent misinterpretation of NRC guidance on nozzles
  - PG&E demonstrated nozzle materials do not restrict plant operability more than the beltline weld

# Deficient Materials

- **Concern**

- “There are known metallurgical flaws in the Unit 1 reactor vessel, excessive copper and nickel impurities in welds and plate metals”
- “It is well documented that there were engineering errors made in the metallurgical specifications of Unit 1 plate and weld alloys”

- Unit 1 steel chemistry typical before 1973
- Specifications based on contemporary knowledge
- Embrittlement of higher copper materials accounted for
  - Plants with more copper than Unit 1 operate safely
  - 25 units with more copper Unit 1 remain in service today



## Wrap Up

# Wrap Up

- **PG&E's current reactor vessel integrity calculations were confirmed and validated**
  - Unit 1 meets the NRC requirements for reactor vessel integrity though 60 years of service
  - Credibility of data was correctly assessed
  - Sister plant data was correctly used
  - Deferrals of Capsule B testing were appropriate
  - Vessel inspection schedule is appropriate
- **Capsule B is scheduled for withdrawal during the 2025 refueling outage**
  - Removal is recommended by 2028 to be consistent with NRC guidance
  - These new data may change the outcome of current RPV integrity assessments
- **Supplemental analyses performed using more data and modern analytical techniques**
  - Pressurized thermal shock: Shows NRC screening criteria very unlikely to be exceeded in 60 years
  - Upper Shelf Energy
    - Shows USE may fall below NRC screening criteria by 2029 or 2030
    - A more accurate analysis following NRC guidance is highly likely to show that acceptable margins will remain past these dates

Thank you for your time!